
## FENCE SPECIFICATION NOTES

- FENCE POSTS 4" SQUARE X 11 GA. (STANDARD, OTHER POSTS APPLICATION SPECIFIC). MINIMUM 50 KSI YIELD AND 55KSI TENSILE MINIMUM G90 GALVANIZED PER ASTM A787 AND A1057
- FENCE PICKETS 5" WIDE, LIQUID COLOR COATED (IN STANDARD COLORS) AND ROLL FORMED .017" THICK FULL-HARD 80 KSI STEEL MINIMUM G90 GALVANIZED PER ASTM A653
  2-COAT THERMO-CURED PAINT SYSTEM CONSISTING OF: PRIMER UNDERCOAT
  FLUOROPOLYMER TOP COAT CONTAINING MINIMUM 70 PERCENT POLYVINYLIDENE DIFLUORIDE BY WEIGHT. COMPLIES WITH THE PHYSICAL PROPERTIES AND COATING PERFORMANCE REQUIREMENTS OF AAMA 621
- C-CHANNEL RAILS-ROLL FORMED 14 GAUGE GRADE 50 MINIMUM STEEL PER ASTM A653 MINIMUM G90 GALVANIZED
- U-CHANNELS AND RAIL BRACKETS-FORMED 14 GAUGE GRADE 50 MINIMUM STEEL PER ASTM A653 MINIMUM G90 GALVANIZED
- HARDWARE -

PICKET FASTENERS PER ANSI B1.13M SERIES 302 STAINLESS STEEL 6-LOBE PIN-IN SECURITY TRUSS HEAD PULL-OUT STRENGTH 5500 NEWTONS CARRIAGE BOLTS AND NUTS FOR RAIL ATTACHMENT 1/4-20" ASTM F593 18-8 STAINLESS STEEL THREAD-FORMING SCREWS FOR RAIL BRACKET AND CHANNEL ATTACHMENT 1/4-14" 410 STAINLESS STEEL SELF-DRILLING SCREW



## NOTES:

- INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS.
- DO NOT SCALE DRAWING.
- THIS DRAWING IS INTENDED FOR USE BY ARCHITECTS, ENGINEERS, CONTRACTORS, CONSULTANTS AND DESIGN PROFESSIONALS FOR PLANNING PURPOSES ONLY. THIS DRAWING MAY NOT BE USED FOR CONSTRUCTION.
- ALL INFORMATION CONTAINED HERE WAS CURRENT AT THE TIME OF DEVELOPMENT BUT MUST BE REVIEWED AND APPROVED BY THE PRODUCT MANUFACTURER TO BE CONSIDERED ACCURATE.

